



- ① RAIN BIRD ET MANAGER OR ESP-LX MODULAR CONTROLLER WITH ET MANAGER CARTRIDGE
- ② SOLID BARE COPPER WIRE (#10 AWG) FROM GROUNDING ROD TO ET MANAGER OR CONTROLLER. MAKE WIRE AS SHORT AND STRAIGHT AS POSSIBLE
- ③ COVER GROUNDING ROD WITH #10 ROUND VALVE BOX AS SHOWN
- ④ 5/8-INCH X 10 FT COPPER CLAD GROUNDING ROD OR GROUNDING PLATE. INSTALL RODS IN SOIL IN A TRIANGULAR PATTERN SPACED A MINIMUM OF 16 FT APART FROM EACH OTHER. GROUNDING GRID TO HAVE A RESISTANCE OF TEN (10) OHMS OR LESS
- ⑤ BARE COPPER WIRE (#6 AWG MIN.) BETWEEN GROUNDING ROD AND GROUNDING PLATE
- ⑥ GROUND ROD CLAMP OR WELDS
- ⑦ COPPER GROUNDING PLATE
- ⑧ GROUND ENHANCEMENT MATERIAL (IF REQUIRED)
- ⑨ FINISH GRADE

D

Grounding Grid

N.T.S.

Grounding Plate Design Layout

2-02-09