



- ① RAIN BIRD FS100 SERIES 1-INCH FLOW SENSOR. WIRE TO RAIN BIRD PT3002 OR PT322 PULSE TRANSMITTER.
- ② 1-INCH DIAMETER PIPE
- ③ 1-INCH PRESSURE REDUCING NORMALLY CLOSED MASTER VALVE. WIRE TO MASTER VALVE 2 CIRCUIT ON NEAREST SATELLITE
- ④ ELL (TYPICAL)

- ⑤ TEE
- ⑥ REDUCER
- ⑦ PRESSURE REDUCING NORMALLY CLOSED MASTER VALVE (SIZE AS REQUIRED). WIRE TO MASTER VALVE 1 CIRCUIT ON NEAREST SATELLITE
- ⑧ RAIN BIRD MODEL FS350B FLOW SENSOR MOUNTED IN 2-INCH NPT THREADOLET. WIRE TO RAIN BIRD PT3002 OR PT322 PULSE TRANSMITTER

NOTE:
 STATION 24 (STATION 12 ON ESP-12-SAT) ON NEAREST SATELLITE SHOULD BE LEFT OPEN FOR MAXICOM MASTER VALVE OPERATIONS.

610

MAXICOM DUAL FLOW SENSORS

N.T.S.

NORMALLY CLOSED MASTER VALVES

08-09-2012